

REPORT NUMBER: ITL85313

ISSUE DATE: 07/30/15

PAGE: 1 OF 9

PREPARED FOR: LED ROADWAY LIGHTING LTD.

CATALOG NUMBER: NXT 12C 5 X 2ES B XX 3 XX X XX X

LUMINAIRE: CAST METAL HOUSING WITH GRAY PAINTED INTERIOR FINISH, 1 WHITE CIRCUIT BOARD WITH 12 LEDS, 1 CLEAR PLASTIC LENS WITH 1 OPTIC PER LED, CLEAR FLAT GLASS LENS IN CAST GRAY PAINTED METAL DOOR FRAME.

LAMPS: TWELVE WHITE LIGHT EMITTING DIODES (LEDs), VERTICAL BASE-UP POSITION.

INPUT ELECTRICAL: 120.0 VOLTS, 42.5 WATTS, 0.354 AMPS

LED DRIVER: LED ROADWAY LIGHTING LRL66164-LF, DRIVER HAS MULTIPLE LEADS, ONLY LINE INPUT AND LED OUTPUT LEADS CONNECTED FOR THIS TEST, CLIENT STATES DRIVER IS 1050mA OUTPUT. LRLM-WH91/92-OU1 SURGE PROTECTOR.

NOTE: DATA SHOWN IS ABSOLUTE FOR THE SAMPLE PROVIDED AT RATED INPUT VOLTAGE (120VAC, 60Hz) TO THE DRIVER AND SURGE PROTECTOR. LED DRIVER AND SURGE PROTECTOR INFORMATION PROVIDED BY CLIENT.

TEST PROCEDURE: IESNA LM-79-08

TEST DISTANCE = 20.0 FEET

TOTAL LUMEN OUTPUT: 3935

COLOR TEMPERATURE AS MEASURED IN INTEGRATING SPHERE TEST # ITL85315: 3814K

COLOR RENDERING INDEX AS MEASURED IN INTEGRATING SPHERE TEST # ITL85315: 73

LED DC DRIVE CURRENT (mA): 1050 (PROVIDED BY CLIENT)


POWER FACTOR: 100.0 %

BUG RATING: B1 U0 G1

LUMINAIRE EFFICACY: 92.6 lm/W

IES CLASSIFICATION: Medium, Type II

**CUTOFF DESIGNATION IS NOT INTENDED TO BE USED WITH ABSOLUTE PHOTOMETRIC TESTS.



FLUX DISTRIBUTION

LUMENS	DOWNWARD	UPWARD	TOTALS
HOUSE SIDE	1341	0	1341
STREET SIDE	2594	0	2594
TOTALS	3935	0	3935

TESTING WAS PERFORMED IN ACCORDANCE WITH IESNA LM-79-08
TEST ANGULAR INCREMENTS AND REPORT FORMATTING WAS BASED ON IESNA LM-31-95

THIS REPORT IS BASED ON PUBLISHED INDUSTRY PROCEDURES. FIELD PERFORMANCE MAY DIFFER FROM LABORATORY PERFORMANCE.



itl boulder
THE LIGHT CENTER OF THE INDUSTRY SINCE 1955

PHONE: (303) 442-1255

FAX: (970) 535-3114

E-MAIL: itl@itlboulder.com

WEBSITE: www.itlboulder.com


NVLAP
NVLAP LAB CODE: 200925-0

INDEPENDENT TESTING LABORATORIES, INC.

4066 CAMELOT CIRCLE, LONGMONT, CO 80504 USA

ISOFOOTCANDLE LINES OF HORIZONTAL ILLUMINATION

Values based on 30 foot mounting height.



REPORT NUMBER: ITL85313

ISSUE DATE: 07/30/15

PAGE: 2 OF 9

PREPARED FOR: LED ROADWAY LIGHTING LTD.

CATALOG NUMBER: NXT 12C 5 X 2ES B XX 3 XX X XX X

LUMINAIRE: CAST METAL HOUSING WITH GRAY PAINTED INTERIOR FINISH, 1 WHITE CIRCUIT BOARD WITH 12 LEDS, 1 CLEAR PLASTIC LENS WITH 1 OPTIC PER LED, CLEAR FLAT GLASS LENS IN CAST GRAY PAINTED METAL DOOR FRAME.

LAMPS: TWELVE WHITE LIGHT EMITTING DIODES (LEDs), VERTICAL BASE-UP POSITION.

INPUT ELECTRICAL: 120.0 VOLTS, 42.5 WATTS, 0.354 AMPS

LED DRIVER: LED ROADWAY LIGHTING

LRL66164-LF, DRIVER HAS MULTIPLE LEADS, ONLY LINE INPUT AND LED OUTPUT LEADS

CONNECTED FOR THIS TEST, CLIENT STATES DRIVER IS 1050mA OUTPUT. LRLM-WH91/92-OU1

SURGE PROTECTOR.

NOTE: DATA SHOWN IS ABSOLUTE FOR THE SAMPLE PROVIDED AT RATED INPUT VOLTAGE (120VAC, 60Hz) TO THE DRIVER AND SURGE PROTECTOR. LED DRIVER AND SURGE PROTECTOR INFORMATION PROVIDED BY CLIENT.

TEST PROCEDURE: IESNA LM-79-08

TEST DISTANCE = 20.0 FEET


IES Classification: Medium, Type II

----- 1/2 Maximum Candela trace

X Maximum Candela point

Checked *B. HYRE*

Approved *R. BEATTIE*
Lighting Engineer



REPORT NUMBER: ITL85313
ISSUE DATE: 07/30/15 PAGE: 3 OF 9
PREPARED FOR: LED ROADWAY LIGHTING LTD.
CATALOG NUMBER: NXT 12C 5 X 2ES B XX 3
XX X XX X

LUMINAIRE: CAST METAL HOUSING WITH GRAY
PAINTED INTERIOR FINISH, 1 WHITE
CIRCUIT BOARD WITH 12 LEDS, 1 CLEAR
PLASTIC LENS WITH 1 OPTIC PER LED,
CLEAR FLAT GLASS LENS IN CAST GRAY
PAINTED METAL DOOR FRAME.

LAMPS: TWELVE WHITE LIGHT EMITTING
DIODES (LEDs), VERTICAL BASE-UP
POSITION.

INPUT ELECTRICAL: 120.0 VOLTS, 42.5
WATTS, 0.354 AMPS


LED DRIVER: LED ROADWAY LIGHTING
LRL66164-LF, DRIVER HAS MULTIPLE
LEADS, ONLY LINE INPUT AND LED OUTPUT
LEADS CONNECTED FOR THIS TEST, CLIENT
STATES DRIVER IS 1050mA OUTPUT. LRLM-
WH91/92-OU1 SURGE PROTECTOR.

NOTE: DATA SHOWN IS ABSOLUTE FOR THE
SAMPLE PROVIDED AT RATED INPUT VOLTAGE
(120VAC, 60Hz) TO THE DRIVER AND SURGE
PROTECTOR. LED DRIVER AND SURGE
PROTECTOR INFORMATION PROVIDED BY
CLIENT.

TEST PROCEDURE: IESNA LM-79-08

TEST DISTANCE = 20.0 FEET

MAXIMUM PLANE AND MAXIMUM CONE PLOTS OF CANDELA






REPORT NUMBER: ITL85313
ISSUE DATE: 07/30/15
PREPARED FOR: LED ROADWAY LIGHTING LTD.

PAGE: 4 OF 9


COEFFICIENTS OF UTILIZATION AND FLUX DISTRIBUTION



	LUMENS	PERCENT OF FIXTURE
DOWNWARD STREET SIDE	2594	65.9
DOWNWARD HOUSE SIDE	1341	34.1
DOWNWARD TOTAL	3935	100.0
UPWARD STREET SIDE	0	0.0
UPWARD HOUSE SIDE	0	0.0
UPWARD TOTAL	0	0.0
TOTAL FLUX	3935	100.0

EFFICACY = 92.6 lm/W

ALL CANDELA AND LUMENS IN THIS REPORT ARE BASED ON ABSOLUTE PHOTOMETRY.
THE COEFFICIENT OF UTILIZATION VALUES ARE BASED ON THE TOTAL ABSOLUTE
LUMEN OUTPUT OF THIS LUMINAIRE SAMPLE.



itl boulder
THE LIGHT CENTER OF THE INDUSTRY SINCE 1955

PHONE: (303) 442-1255 • FAX: (970) 535-3114 • E-MAIL: itl@itlboulder.com • WEBSITE: www.itlboulder.com



INDEPENDENT TESTING LABORATORIES, INC.
4066 CAMELOT CIRCLE, LONGMONT, CO 80504 USA

REPORT NUMBER: ITL85313
ISSUE DATE: 07/30/15
PREPARED FOR: LED ROADWAY LIGHTING LTD.

PAGE: 5 OF 9


FLUX DISTRIBUTION BY SOLID ANGLE

(PER IESNA TM-15-11, LUMINAIRE CLASSIFICATION
SYSTEM FOR OUTDOOR LUMINAIRES)

	LUMENS	PERCENT OF FIXTURE	BUG ZONE RATINGS
FORWARD LIGHT	2594.	65.9	
FL (0- 30)	469.0	11.9	
FM (30- 60)	1348.9	34.3	
FH (60- 80)	755.7	19.2	G1
FVH(80- 90)	20.2	0.5	G1
BACK LIGHT	1341.	34.1	
BL (0- 30)	355.6	9.0	B1
BM (30- 60)	684.8	17.4	B1
BH (60- 80)	291.2	7.4	B1 G1
BVH(80- 90)	9.4	0.2	G0
UPLIGHT	0.	0.0	
UL (90-100)	0.0	0.0	U0
UH (100-180)	0.0	0.0	U0
TRAPPED LIGHT	0.	0.0	
TOTAL FLUX	3935.	100.0	

BACKLIGHT, UPLIGHT, AND GLARE (BUG) RATINGS
(PER ADDENDUM A FOR IESNA TM-15-11)

BUG RATING: B1 U0 G1



itl boulder
THE LIGHT CENTER OF THE INDUSTRY SINCE 1955

NVLAP
NVLAP LAB CODE: 200925-0

INDEPENDENT TESTING LABORATORIES, INC.
4066 CAMELOT CIRCLE, LONGMONT, CO 80504 USA


PHONE: (303) 442-1255 • FAX: (970) 535-3114 • E-MAIL: itl@itlboulder.com • WEBSITE: www.itlboulder.com

REPORT NUMBER: ITL85313
ISSUE DATE: 07/30/15
PREPARED FOR: LED ROADWAY LIGHTING LTD.

PAGE: 6 OF 9

CANDELA TABULATION

	STREET SIDE										
	0.0	5.0	15.0	25.0	35.0	45.0	55.0	65.0	73.0	75.0	85.0
	180.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	175.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	165.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	155.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	145.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	135.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	125.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	115.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	105.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	95.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	92.5	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	90.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	87.5	1.	1.	1.	2.	2.	2.	2.	2.	3.	3.
	85.0	3.	3.	4.	4.	4.	5.	5.	8.	9.	10.
V	82.5	7.	6.	10.	10.	10.	13.	14.	42.	205.	139.
E	80.0	19.	19.	29.	19.	22.	24.	29.	204.	743.	477.
R	77.5	25.	26.	32.	30.	35.	38.	58.	744.	1280.	828.
T	75.0	35.	36.	45.	48.	48.	60.	117.	1318.	1839.	1115.
I	72.5	54.	54.	61.	64.	64.	107.	397.	1871.	2460.	1287.
C	72.0<<	58.	57.	64.	67.	68.	120.	481.	1939.	2476.	1311.
A	70.0	75.	72.	78.	82.	97.	263.	837.	2111.	2302.	1398.
L	67.5	101.	101.	103.	128.	198.	550.	1222.	2164.	2088.	1463.
	65.0	163.	167.	190.	258.	424.	877.	1520.	2099.	2029.	1548.
A	62.5	273.	278.	316.	426.	663.	1086.	1540.	1968.	1957.	1581.
N	60.0	402.	406.	450.	558.	753.	1093.	1477.	1888.	1879.	1610.
G	57.5	501.	504.	538.	623.	791.	1099.	1450.	1822.	1824.	1630.
L	55.0	568.	570.	594.	671.	830.	1104.	1428.	1772.	1791.	1673.
E	52.5	611.	612.	643.	719.	867.	1108.	1403.	1696.	1742.	1696.
	50.0	646.	649.	684.	770.	894.	1117.	1384.	1622.	1684.	1689.
	47.5	684.	685.	728.	809.	926.	1131.	1368.	1545.	1613.	1669.
	45.0	724.	726.	771.	850.	973.	1150.	1356.	1477.	1552.	1633.
	42.5	764.	767.	813.	914.	1033.	1176.	1348.	1427.	1498.	1578.
	40.0	813.	821.	894.	990.	1087.	1208.	1320.	1380.	1450.	1511.
	37.5	939.	947.	1007.	1070.	1132.	1242.	1276.	1327.	1390.	1445.
	35.0	1056.	1061.	1101.	1131.	1174.	1246.	1225.	1282.	1345.	1387.
	30.0	1161.	1164.	1180.	1204.	1189.	1137.	1150.	1226.	1278.	1276.
	25.0	1153.	1155.	1142.	1103.	1065.	1067.	1128.	1190.	1224.	1179.
	20.0	1013.	1013.	1016.	1019.	1038.	1091.	1131.	1162.	1165.	1100.
	15.0	1040.	1039.	1059.	1080.	1096.	1114.	1129.	1127.	1109.	1045.
	10.0	1100.	1105.	1113.	1117.	1116.	1114.	1104.	1083.	1050.	1011.
	5.0	1080.	1081.	1085.	1080.	1067.	1054.	1036.	1017.	1007.	990.
	0.0	984.	984.	984.	984.	984.	984.	984.	984.	984.	984.
									PLANE OF MAXIMUM CANDELA		
									CONE OF MAXIMUM CANDELA		



itl boulder
THE LIGHT CENTER OF THE INDUSTRY SINCE 1955

NVLAP
NVLAP LAB CODE: 200925-0

INDEPENDENT TESTING LABORATORIES, INC.
4066 CAMELOT CIRCLE, LONGMONT, CO 80504 USA

PHONE: (303) 442-1255 • FAX: (970) 535-3114 • E-MAIL: itl@itlboulder.com • WEBSITE: www.itlboulder.com

REPORT NUMBER: ITL85313
ISSUE DATE: 07/30/15
PREPARED FOR: LED ROADWAY LIGHTING LTD.

PAGE: 7 OF 9

CANDELA TABULATION

HOUSE SIDE		LATERAL ANGLE										
		90.0	95.0	105.0	115.0	125.0	135.0	145.0	155.0	165.0	175.0	180.0
	180.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	175.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	165.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	155.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	145.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	135.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	125.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	115.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	105.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	95.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	92.5	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	90.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	87.5	3.	3.	2.	2.	2.	1.	0.	0.	0.	0.	0.
	85.0	9.	9.	8.	7.	6.	5.	4.	2.	1.	0.	0.
V	82.5	116.	114.	20.	16.	15.	17.	16.	13.	12.	2.	2.
E	80.0	428.	390.	85.	30.	27.	36.	37.	36.	37.	9.	4.
R	77.5	729.	699.	216.	54.	44.	59.	65.	66.	73.	69.	68.
T	75.0	979.	916.	420.	90.	63.	81.	86.	88.	109.	115.	112.
I	72.5	1127.	1024.	559.	134.	83.	96.	105.	108.	133.	148.	150.
C	72.0<<	1155.	1050.	581.	141.	88.	98.	108.	111.	137.	150.	153.
A	70.0	1250.	1139.	674.	171.	105.	106.	114.	114.	145.	151.	152.
L	67.5	1341.	1239.	811.	209.	127.	118.	117.	114.	141.	140.	140.
	65.0	1438.	1339.	928.	251.	140.	134.	123.	114.	121.	126.	125.
A	62.5	1494.	1406.	1030.	315.	152.	148.	135.	126.	116.	106.	105.
N	60.0	1552.	1486.	1135.	406.	165.	158.	146.	140.	127.	113.	110.
G	57.5	1602.	1550.	1233.	530.	179.	166.	153.	152.	142.	126.	123.
L	55.0	1652.	1607.	1313.	666.	197.	172.	164.	163.	158.	142.	139.
E	52.5	1680.	1645.	1373.	788.	227.	183.	177.	179.	173.	157.	154.
	50.0	1690.	1665.	1407.	893.	299.	196.	189.	191.	186.	171.	169.
	47.5	1677.	1659.	1425.	970.	396.	214.	203.	200.	194.	187.	186.
	45.0	1645.	1628.	1423.	1017.	498.	249.	218.	214.	210.	206.	206.
	42.5	1584.	1570.	1395.	1041.	589.	307.	235.	226.	225.	224.	224.
	40.0	1512.	1501.	1353.	1050.	663.	373.	270.	239.	233.	233.	233.
	37.5	1443.	1435.	1311.	1050.	720.	444.	317.	269.	252.	245.	245.
	35.0	1379.	1367.	1259.	1041.	764.	512.	367.	310.	288.	278.	279.
	30.0	1258.	1241.	1163.	1015.	829.	648.	501.	412.	369.	355.	353.
	25.0	1155.	1136.	1081.	990.	877.	760.	654.	571.	523.	504.	500.
	20.0	1077.	1061.	1027.	976.	913.	846.	781.	729.	695.	673.	671.
	15.0	1028.	1015.	995.	968.	938.	904.	878.	849.	828.	822.	817.
	10.0	1000.	991.	979.	967.	955.	943.	933.	921.	914.	917.	914.
	5.0	986.	982.	976.	968.	963.	960.	959.	955.	953.	959.	957.
	0.0	984.	984.	984.	984.	984.	984.	984.	984.	984.	984.	984.

CONE OF MAXIMUM CANDELA



INDEPENDENT TESTING LABORATORIES, INC.
4066 CAMELOT CIRCLE, LONGMONT, CO 80504 USA

PHONE: (303) 442-1255 • FAX: (970) 535-3114 • E-MAIL: itl@itlboulder.com • WEBSITE: www.itlboulder.com

REPORT NUMBER: ITL85313
ISSUE DATE: 07/30/15
PREPARED FOR: LED ROADWAY LIGHTING LTD.

PAGE: 8 OF 9

5-DEGREE
ZONAL LUMEN SUMMARY

0- 5	24
5- 10	73
10- 15	120
15- 20	162
20- 25	202
25- 30	244
30- 35	283
35- 40	313
40- 45	337
45- 50	358
50- 55	371
55- 60	372
60- 65	357
65- 70	310
70- 75	247
75- 80	133
80- 85	29
85- 90	1
90- 95	0
95-100	0
100-105	0
105-110	0
110-115	0
115-120	0
120-125	0
125-130	0
130-135	0
135-140	0
140-145	0
145-150	0
150-155	0
155-160	0
160-165	0
165-170	0
170-175	0
175-180	0

10-DEGREE
ZONAL LUMEN SUMMARY

0- 10	96
0- 20	378
0- 30	825
0- 40	1420
0- 50	2115
0- 60	2858
0- 70	3525
0- 80	3905
0- 90	3935
0-100	3935
0-110	3935
0-120	3935
0-130	3935
0-140	3935
0-150	3935
0-160	3935
0-170	3935
0-180	3935



itl boulder
THE LIGHT CENTER OF THE INDUSTRY SINCE 1955



INDEPENDENT TESTING LABORATORIES, INC.
4066 CAMELOT CIRCLE, LONGMONT, CO 80504 USA

PHONE: (303) 442-1255 • FAX: (970) 535-3114 • E-MAIL: itl@itlboulder.com • WEBSITE: www.itlboulder.com

REPORT NUMBER: ITL85313
ISSUE DATE: 07/30/15
PREPARED FOR: LED ROADWAY LIGHTING LTD.

PAGE: 9 OF 9

ADDRESS: 115 CHAIN LAKE DRIVE
SUITE 201
HALIFAX, NOVA SCOTIA, CANADA B3S1B3

THIS ITL REPORT WITH THE USE OF THE NVLAP LOGO SHALL NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY NVLAP, NIST, OR ANY AGENCY OF THE FEDERAL GOVERNMENT.